

ANNUAL WATER QUALITY REPORT CERTIFICATION FORM

NAME OF WATER SYSTEM: **Bovina Center Water District**

PUBLIC WATER SUPPLY ID #: **NY1200251**

The community water system named above hereby confirms that its Annual Water Quality Report (AWQR) has been distributed to customers and appropriate notices of availability have been given. Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the health department.

Certified by: Name: Tina B. Mole'
Title: Supervisor
Phone #: 607-832-4302 Date: 4-21-22

Please indicate how your report was distributed to your customers:

- AWQR was distributed to bill-paying customers by mail.
- AWQR was distributed by other direct delivery method(s) (check all that apply)
- Hand delivered.
- Published in local paper (i.e., *Penny Saver*) that was directly delivered or mailed to all bill-paying customers.
- Published in local municipal newsletter that was directly delivered or mailed.
- Mailed a notification that AWQR is available on a public website via a direct URL
- Emailed with a message containing a direct URL link to the AWQR
- Emailed with AWQR sent as an attachment to the email
- Emailed with AWQR sent as an embedded image in the email
- Additional electronic delivery that meets "otherwise directly deliver" requirement
- Other (please specify) placed on website + available from Town Clerk
- System does not have bill-paying customers.
- For systems serving at least 100,000 persons: in addition to direct delivery to bill-paying customer the AWQR was posted on a publicly-accessible website at www.

Please indicate what "Good Faith" efforts were used to reach non-bill paying consumers (check all that apply).

- Posting the Annual Water Quality Report on the Internet at www.bovinany.org
- Mailing the Annual Water Quality Report to postal patrons within the service area
- Advertising the availability of the Annual Water Quality Report in the news media
- Publication of the Annual Water Quality Report in a local newspaper
- Posting the Annual Water Quality Report in public places (attach a list of locations)
- Delivery of multiple copies to single-bill addresses serving several persons such as: apartments, businesses, and large private employers
- Delivery to community organizations
- Other (please specify) _____

Annual Drinking Water Quality Report for 2021
Bovina Water District #1
PO Box 6, Bovina Center, NY 13740
Public Water Supply ID# NY 1200251

INTRODUCTION

To comply with State regulations, the Bovina Water District, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Bovina Town Supervisor, Tina Mole', at 607-832-4302 or the Bovina Water Superintendent Andrew Serrao at 845-676-3990. We want you to be informed about your drinking water.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves 142 people through 59 service connections. Our water source is from two sources. The primary source is a well located off Coulter Brook Road. The well water is chlorinated prior to entering the storage tank. The secondary/back up source is Coulter Brook. This surface water supply is treated with polymer and chlorination prior to entering a conventional filter system. On average, the water district uses approximately 15,000 gallons of water per day.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, lead and copper, total trihalomethanes, haloacetic acids, PFOS, PFOA and 1,4-dioxane and radiological compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and

Annual Drinking Water Quality Report for 2021

Bovina Water District #1

potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the NYS Department of Health, Oneonta District Office at 607-432-3911.

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, lead and copper, and total trihalomethanes.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Dates of Samples	Level Detected (Avg/Max) (Range)	Unit Measurement	Regulatory Limit (MCL, TT or AL)	MCLG	Likely Source of Contamination
Nitrate	No	10-21-2021	Well - .27	mg/l	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Total Trihalomethanes (THMs - chloroform, bromodichloromethane, dibromochloromethane, and bromoform)	No	9-23-2021	30.31	ug/l	80	N/A	By-product of drinking water chlorination needed to kill harmful organisms. THMs are formed when source water contains organic matter.
Haloacetic Acids (mono-, di-, and trichloroacetic acid, and mono- and dibromoacetic acid)	No	9-23-2021	8.5	ug/l	60	N/A	By-product of drinking water disinfection needed to kill harmful organisms.
Copper	No	12-2021	0.173 ¹	mg/l	1.3	1.3	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.
Lead	No	12-2021	1 ²	ug/l	15	0	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.
Perfluorooctanoic Acid (PFOA)	No	12-2021	ND	ng/L	10	N/A	Released into the environment from widespread use in commercial and industrial applications.
Perfluorooctane Sulfonic Acid (PFOS)	No	12-2021	ND	ng/L	10	N/A	Released into the environment from widespread use in commercial and industrial applications.
1,4-Dioxane	No	12-2021	ND	ug/L	1	N/A	Released into the environment from widespread use in commercial and industrial sources and is associated with inactive and hazardous waste sites.
Gross alpha activity (including radium - 226 but excluding radon and uranium)	No	9/2017	Well - 1.35	pCi/l	15	0	Erosion of natural deposits.
Beta particle and photon activity from manmade radionuclides	No	9/2017	Well - 2.78	pCi/l	50 ²	0	Decay of natural deposits and man-made emissions.
Barium	No	11-2020 3/2016	Well - 0.026 Filter - 0.0051	mg/l	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Arsenic	No	7-7-2021	Filter Plant - <0.0005	ug/l	10	N/A	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Fluoride	No	11/2017	Well - 0.18	mg/l	2.2	N/A	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories.
Manganese	No	11/2016	Filter - 3	ug/l	300	N/A	Naturally occurring; Indicative of landfill contamination.
Sodium	No	11/2016	Filter - 2.6	mg/l	(see Health Effects) ³	N/A	Naturally occurring; Road salt; Water softeners; Animal waste.
Sulfate	No	11/2016	Filter - 4	mg/l	250	N/A	Naturally occurring.
Zinc	No	11/2016	Filter - 0.005	mg/l	5	N/A	Naturally occurring; Mining waste.

Notes:

1. The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, ten samples were collected at your water system and the 90th percentile value was the second highest value (0.068 mg/l). The action level for copper was not exceeded at any of the sites tested.
2. The level presented represents the 90th percentile of the (include number of samples, e.g. ten samples) samples collected. The action level for lead was exceeded at none of the 10 sites tested.
3. The State considers 50 pCi/l to be the level of concern for beta particles.
4. Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2020, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.